



**PLAN NOTES:**

- ① 12X12 Q-3 TRANSFER GRILLE
- ② 12X12 Q-3 EXHAUST GRILLE.
- ③ 12X12 EXHAUST DUCT
- ④ 12"Ø EXHAUST DUCT
- ⑤ 12X10 EXHAUST DUCT
- ⑥ 64/16 SPLIT 24-40. SEE DETAIL 6/M-601.
- ⑦ 8X8 Q-3 EXHAUST GRILLE, 100 CFM.
- ⑧ SEAL OFF TOP OF EXH. CHASE & CONNECT EXH. DUCT, TYP.
- ⑨ 10X10 Q-3 EXHAUST GRILLE, 100 CFM.

**GENERAL NOTES:**

- 1. SUPPLY DIFFUSERS SHALL BE TYPE D-1 U.O.N.
- 2. PROVIDE 24"x12"x1" THICK AIR FILTER AT EXHAUST OUTLETS IN ISOLATION ROOMS AND TREATMENT ROOMS. SEE DETAIL 2/A-101.
- 3. UNDERCUT DOORS 1" TO ROOMS 112, 113 & 114.

**HVAC SHEET METAL PLAN**

SCALE: 1/4"=1'-0"



Project:		VETERINARY MEDICINE ISOLATION FACILITY-2003	
Scale:		1/4"=1'-0"	
Date:	OCTOBER 07, 2003	Revision:	
Drawing By:		Sheet:	
CAD File:			